



## Proposed Code Change

State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

### FOR OFFICE USE ONLY

Received 6-20-09

Code 62.4.7-09

#### INSTRUCTIONS:

*Only TYPED copy accepted.*

*(KEY – Dashed line through material to be deleted, underline material to be added)*

*Use second sheet for any material requiring more space.*

Code Title Indiana Residential Code		Edition 2009
Section number and title E3902.9		Page 683
Proponent Charlie Eldridge	Title Consultant	
Address 551 Grassy Ln., Indianapolis, IN 46217		Phone (317) 370-3444
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p><b>E3902.9 Boat hoists.</b> Ground-fault circuit-interrupter protection for personnel shall be provided for <del>240-volt and less outlets that supply the supply to</del> boat hoists.</p>		
REASON AND FISCAL IMPACT		
Direct wired units should also be protected due to the presence of the water and people with wet and bare feet and hands.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		